

# Permit/Checklist for Heta Arbeten®

Workplace:.....

Alarm address:.....

Work method:  Welding  Angle grinding  Cutting  Soldering  Hot air  Asphalt mix  
 Other.....

Permit is valid from ..... at ..... until ..... at .....  
(The permit must be issued for as short a time as possible, normally no longer than one day/one shift)

Does the work constitute a fire hazard? (MME method)  Yes  No

## Yes No

- 0  The permit issuer is appointed.
- 1  The person who will carry out the work is qualified to perform Hot Work.
- 2 a  Monitoring and checking after each period of work is organised through the competent fire-watcher.  
Name(s) of fire-watcher(s): .....
- 2 b  The permit issuer considers that a fire-watcher is clearly not needed during this work.  
 Post-work monitoring (always at least one hour) has been arranged through the competent fire-watcher.  
Different, longer time: ..... Fire-watcher for post-work monitoring, name: .....
- 3  A permit for working in areas that contain/have contained a flammable product must be obtained from the person appointed superintendent for the handling of such products.
- 4  The workplace is tidy and if necessary wetted down.
- 5  Combustible material in and near the workplace is removed, protected by covering and/or screened off.
- 6 a  There are heat-conducting constructions and concealed combustible structural elements.
- 6 b  These are protected and accessible for immediately extinguishing fire.
- 7 a  There are gaps, holes, penetrations and other openings in and near the workplace.
- 7 b  These are sealed or checked and protected.
- 8  Approved, working and sufficient fire-fighting equipment of the correct type is available to immediately extinguish fire.
- 9 a  Welding equipment will be used during the work.
- 9 b  Welding equipment is free from defects. The acetylene cylinder is fitted with backfire protection. Blowpipes are fitted with check valves for fuel gas and oxygen. Protective gloves and a stop key are available.
- 10  The emergency services/fire brigade can be alerted immediately.
- 11a  During waterproofing or other drying/heating, the gas flame is enclosed.
- 11b  The permit issuer permits naked flame to be used to melt snow and ice.
- 12  During the drying of underlay and the application of waterproofing, the material is heated to max. 300°C.
- 13  For the melting of asphalt, the equipment should be handled in accordance with the Swedish Fire Protection Association's document entitled "Melting asphalt when working on roofs and balconies".

The following sections/addresses in the automatic fire alarm are disconnected during the work (use form SBF 175)

**Signature of permit issuer** All safety regulations have been taken into consideration and work can commence

Signature Name in bold letters Telephone number

**Signature of Hot Work operative (HW) and fire-watcher (FW)** Certificate check performed (by permit issuer) HW FW

Signature Name in bold letters

Signature Name in bold letters

Signature Name in bold letters

**Signature of permit issuer** Work is completed, post-work monitoring performed and fire protection at the workplace has been checked.

Signature Name in bold letters